



**CAN LIGHT CONFLICTS WITH DUCT WORK**

ASI-26 issued to the Contractor, relocates the lights that were in conflict with the incorrectly installed duct work.

