



Joe Lauro, CPPO/CPPB
Director

September 24, 2015

TO: ALL PREQUALIFIED BIDDERS
INVITATION TO BID: UV FACILITY MODIFICATIONS - SCBWRF
BID NUMBER: 145-0474-CP(DF)
BID SUBMITTAL IS DUE: September 29, 2015 @ 3:00 PM

ADDENDUM NO. 1

Following is additional information, clarifications, questions and responses relative to referenced Invitation to Bid (ITB):

Additional Information

The Bid Submittal Sheet in Section E of the Invitation to Bid has been revised to include allowance for Permitting in the Contingency line item amount. Please refer to the attachment to this addendum titled "Bid Submittal Sheet - Addendum No. 1." Please use this form for bid submittal.

Specifications Section 00 75 00 Special Provisions and Section 01 20 01 Measurement and Payment have been revised. Please refer to the attachments to this addendum titled "00 75 00 Special Provisions-Addendum No. 1" and "01 20 01 Measurement and Payment-Addendum No. 1." Please note that revisions made to Special Provisions and Measurement and Payment are noted and underlined in the attachments.

Please see additional attachments to this addendum entitled "Asbestos and Lead Report-Addendum No.1" and "Drain Channels Sketch-Addendum No. 1."

The above documents must be downloaded as files from the Pinellas County Purchasing Department FTPS web site at <https://files.pinellascounty.org/purchasing>.

PLEASE ADDRESS REPLY TO:
400 South Ft. Harrison Avenue, Sixth Floor
Clearwater, Florida 33756
Phone: (727) 464-3311
FAX: (727) 464-3925
Website: www.pinellascounty.org/purchase



Question/Response

Question No. 1: I see a few references in the specifications to a "Lead Paint and Asbestos Survey". It even mentions that it is part of the documents, but I do not see it in the documents. Could you please provide?


Response: The 2012 UV Asbestos Survey and Lead Paint Screening Report is attached and made part of this addendum (for informational purposes) and titled "Asbestos and Lead Report-Addendum No. 1." Please note the EQ Tank was not included in the Report and should be evaluated for lead and asbestos mitigation as part of this project.

Question No. 2: Please reference the bid form and measurement and payment sections of the specifications. Could you please elaborate on what is meant to be included in bid item #7 "Testing and Verification of Drainage"?

Response: To further clarify Bid item #7 "Testing and Verification of Drainage", please refer to Note #8 on drawing S-310.06 which states "CONTRACTOR TO VERIFY SLOPE OF CONCRETE FILTER BEDS' FLOOR AFTER DEMOLITION WORK. IF BOTTOM FLOOR DOESN'T DRAIN TOWARDS FLOOR DRAIN CONTRACTOR TO RE-GROUT AND SLOPE ACCORDINGLY." Please refer to the attachment to this addendum titled "Drain Channels Sketch-Addendum No. 1." It is marked to represent the intended run-off route (toward floor drains located at the common effluent channel).

All other specifications, terms and conditions remain the same.

Please remember to acknowledge receipt of this Addendum in Section F, Page 47 under Addendum No. 1 and return with completed bid package.

Sincerely,

Joe Lauro, CPPO/CPPB
Director of Purchasing