



REPORT OF SPRAYED FIRE-RESISTIVE MATERIALS THICKNESS

Project Name: <u>St. Petersburg/Clearwater Airport Terminal Expansion Ph III</u>				Date Tested: <u>6/15/2017</u>			
Project Location: <u>Pinellas County, Florida</u>				Tested By: <u>M Shirkey</u>			
File Number: <u>16-54-9705</u>				Lab Number: <u>N/A</u>			
Client Name: <u>Tierra</u>				Report No.: <u>2</u>			

MEMBER SPRAYED:						Required Thickness _____ in.	
Columns						Required Thickness - 25% _____ in.	
						Required Thickness + 1/4" _____ in.	

Location	B-6			D-3						
	Readings			Readings			Readings			
Reading No.	Field	Adjusted	P/F	Field	Adjusted	P/F	Field	Adjusted	P/F	
1	1 8/16	0		1 4/16	0					
	1 8/16	0		1 8/16	0					
2	2	0		14/16	0					
	1 4/16	0		1	0					
3	1 8/16	0		1 4/16	0					
	1 4/16	0		1 8/16	0					
4	1 8/16	0		1 12/16	0					
	1 8/16	0		2	0					
5	1 4/16	0		2	0					
	1 4/16	0		2 4/16	0					
6	2	0		1 8/16	0					
	1 12/16	0		1 12/16	0					
7	1	0		1 8/16	0					
	1 8/16	0		1 8/16	0					
8	1 4/16	0		1 8/16	0					
	1 2/16	0		1 6/16	0					
9	1 8/16	0		1 10/16	0					
	1 4/16	0		1 8/16	0					
10	1 2/16	0		1 6/16	0					
	1 8/16	0		1 8/16	0					
11	1 8/16	0		1 4/16	0					
	1 4/16	0		1 4/16	0					
12	1	0		1 4/16	0					
	1	0		1 4/16	0					
Average Value			0	Average Value			0	Average Value		
Individual Reading - Pass/Fail				Individual Reading - Pass/Fail				Individual Reading - Pass/Fail		
COMMENTS										

MEMBER SPRAYED:						Required Thickness _____ in.	
Beams						Required Thickness - 25% _____ in.	
						Required Thickness + 1/4" _____ in.	

Location	<i>Bounded by Lines B to C and Lines 4 to 5</i>			<i>Bounded by Lines B to C and west of Line 3</i>			<i>Bounded by Lines 3 to 4 and south of Line E</i>			
	Readings			Readings			Readings			
Reading No.	Field	Adjusted	P/F *	Field	Adjusted	P/F *	Field	Adjusted	P/F *	
1	2/16	0		12/16	0		8/16	0		
	2/16	0		14/16	0		6/16	0		
2	12/16	0		1	0		12/16	0		
	12/16	0		1 8/16	0		14/16	0		
3	4/16	0		6/16	0		12/16	0		
	2/16	0		8/16	0		8/16	0		
4	4/16	0		1 4/16	0		2/16	0		
	4/16	0		1 2/16	0		4/16	0		
5	1	0		1	0		1	0		
	12/16	0		1 8/16	0		1	0		
6	4/16	0		1 4/16	0		4/16	0		
	2/16	0		1 8/16	0		8/16	0		
7	2/16	0		1 8/16	0		8/16	0		
	2/16	0		1 2/16	0		8/16	0		
8	14/16	0		1	0		1 6/16	0		
	12/16	0		1 8/16	0		2	0		
9	4/16	0		1	0		1	0		
	4/16	0		14/16	0		11/16	0		
Average Value			0	Average Value			0	Average Value		
Individual Reading - Pass/Fail				Individual Reading - Pass/Fail				Individual Reading - Pass/Fail		
COMMENTS										