



## REPORT OF SPRAYED FIRE-RESISTIVE MATERIALS THICKNESS

Project Name: <u>St. Petersburg/Clearwater Airport Terminal Expansion Ph III</u>				Date Tested: <u>6/15/2017</u>					
Project Location: <u>Pinellas County, Florida</u>				Tested By: <u>M Shirkey</u>					
File Number: <u>16-54-9705</u>				Lab Number: <u>N/A</u>					
Client Name: <u>Tierra</u>				Report No.: <u>1</u>					
<b>MEMBER SPRAYED:</b>  <u>Underside of Decking</u>				Required Thickness _____ in.					
				Required Thickness - 25% _____ in.					
				Required Thickness + 1/4" _____ in.					
Location	<i>Bounded By Lines A to B and Lines 5 to 6</i>			<i>Bounded By Lines B to C and Lines 5 to 6</i>			<i>Bounded By Lines A to B and Lines 4 to 5</i>		
Reading No.	Readings			Readings			Readings		
	Field	Adjusted	P/F	Field	Adjusted	P/F	Field	Adjusted	P/F
1	8/16 8/16	0 0		8/16 1	0 0		6/16 6/16	0 0	
2	10/16 3*8	0 0		12/16 10/16	0 0		6/16 8/16	0 0	
3	8/16 8/16	0 0		12/16 1	0 0		12/16 1	0 0	
4	6/16 8/16	0 0		8/16 14/16	0 0		14/16 14/16	0 0	
5	8/16 6/16	0 0		12/16 6/16	0 0		14/16 1	0 0	
6	10/16 8/16	0 0		14/16 14/16	0 0		1 1	0 6/16	
7									
8									
9									
10									
11									
12									
Average Value <span style="float: right;">0</span>									
Individual Reading - Pass/Fail									
<b>COMMENTS</b>									
<b>MEMBER SPRAYED:</b>  <u>Underside of Decking</u>				Required Thickness _____ in.					
				Required Thickness - 25% _____ in.					
				Required Thickness + 1/4" _____ in.					
Location	<i>Bounded By Lines B to C and Lins 3 to 4</i>								
Reading No.	Readings			Readings			Readings		
	Field	Adjusted	P/F *	Field	Adjusted	P/F *	Field	Adjusted	P/F *
1	6/16 4/16	0 0							
2	6/16 6/16	0 0							
3	14/16 12/16	0 0							
4	12/16 14/16	0 0							
5	8/16 14/16	0 0							
6	12/16 12/16	0 0							
7									
8									
9									
Average Value <span style="float: right;">0</span>									
Individual Reading - Pass/Fail									
<b>COMMENTS</b>									