



# Pinellas County

## Legislation Details (With Text)

**File #:** 17-063A      **Version:** 1

**Type:** Contract/Agreement      **Status:** Passed

**File created:** 1/12/2017      **In control:** Utilities

**On agenda:** 6/6/2017      **Final action:** 6/6/2017

**Title:** Award of bid to T.L.C. Diversified, Inc. for the Rotary Drum Thickener Replacement Project at the W.E. Dunn Water Reclamation Facility.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. FE Construction Agreement with T L C Diversified Inc, 2. Agreement.pdf, 3. Project Location Map.pdf

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

**Subject:**

Award of bid to T.L.C. Diversified, Inc. for the Rotary Drum Thickener Replacement Project at the W.E. Dunn Water Reclamation Facility.

**Recommended Action:**

Approve the award of bid to T.L.C. Diversified, Inc. for the Rotary Drum Thickener Replacement Project at W.E. Dunn Water Reclamation Facility.

Bid No. 167-0187-CP(DF); PID No. 002415A; in the amount of \$1,777,777.00 on the basis of being the lowest responsive, responsible bid received meeting specifications; all work is expected to be completed within 375 consecutive calendar days.

Chairman to sign and Clerk of Court to attest.

**Strategic Plan:**

Foster Continual Economic Growth and Vitality

4.4 Invest in infrastructure to meet current and future needs

Deliver First Class Services to the Public and Our Customers

5.2 Be responsible stewards of the public's resources

5.3 Ensure effective and efficient delivery of county services and support

**Summary:**

The purpose of this project is to furnish and install two (2) new rotary drum thickeners (RDTs) replacing the existing RDT, that is at the end of its serviceable life.

The new RDTs will improve reliability to the sludge thickening process and simultaneously will allow the repair and maintenance to occur without interrupting the treatment process.

**Background Information:**

Work includes furnishing and installation of two RDTs, associated pipe, valves, flocculation tanks, a polymer system, and a new covered structural platform. The RDT is required to thicken the waste sludge prior to dewatering and hauling to the South Cross Bayou for pelletizing. The current RDT is at the end of its service life. Since the RDT must operate 24/7, redundant RDTs will allow alternating run times between the two units to allow for maintenance. This will eliminate the need for emergency pumping/hauling of waste sludge for periodic maintenance.

**Fiscal Impact:**

Expenditure not to exceed: \$1,777,777.00

Funding for this project is derived from the Utilities Department Sewer Enterprise Fund.

**Staff Member Responsible:**

Randi Kim, Director, Utilities

Joe Lauro, Director, Purchasing

**Partners:**

N/A

**Attachments:**

Agreement

Bid Tabulation

Project Location Map